



GENERAL NOTES:

1. WATER METER FURNISHED AND INSTALLED BY TODD CREEK VILLAGE METROPOLITAN DISTRICT.
2. **ONLY THE METER IS THE PROPERTY OF THE DISTRICT.**
3. ALL METER PITS SHALL BE STAKED FOR FINISHED GRADE IF INSTALLATION PRECEEDS CONSTRUCTION.
4. WATER DISTRICT PERSONNEL SHALL INSPECT THE SERVICE LINE FROM THE CURB STOP TO THE HOUSE (24 HOUR NOTICE REQUIRED FOR INSPECTION).
5. SERVICES BELOW ELEVATION 5090 MUST USE TANDEM COPPER SETTER WITH PRV.

RG AND ASSOCIATES, LLC
 1331 17TH STREET-SUITE 710-DENVER CO 80202

TODD CREEK VILLAGE METROPOLITAN DISTRICT	
OUTSIDE SETTING FOR 3/4" & 1" METERS (NON POTABLE)	
Scale: <i>NONE</i>	Date: <i>FEB 2010</i>
Approved:	Rev.

IRRIGATION METER PIT DESCRIPTION

Meter Pit (not-potable):

Mid States Plastic 20 x 24 x 48, molded with minimum wall thickness of .055" and vertical load test greater than 20,000 lbs. Has white interior and anti-setting flange. Meter box extensions will bring height to grade on off grade extension or uneven terrain.

Three (3) foot clearance required from center of the meter lid to any structure or plant material.

TODD CREEK VILLAGE
METROPOLITAN DISTRICT

OUTSIDE SETTING FOR 3/4"
& 1" METERS (NON POTABLE)

Scale: *NONE* Date: *FEB 2012*

Approved: _____ Rev. *Jul 2015*

RG AND ASSOCIATES, LLC
1331 17TH STREET-SUITE 710-DENVER CO 80202